



# Certificate of Compliance

**Certificate:** 1063291 (LR 57940-3)

**Master Contract:** 154136

**Project:** 2230310

**Date Issued:** 2009/12/07

**Issued to:** **Werner Turck GmbH & Company KG**

Goethestrasse 7  
Postfach 1565  
Halver, 58553  
Germany  
Attention: Paul E. Harms

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.*



*John Lam*

Issued by: John Lam

## **PRODUCTS**

**CLASS 3211 83** - INDUSTRIAL CONTROL EQUIPMENT-Motor Controllers - Auxiliary Devices-Certified to U.S. Standards

**CLASS 3211 03** - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Auxiliary Devices

CREATION OF MASTER/SATELLITE FORMAT, MASTER FILE LR 57940, SATELLITE LR 88875.

The submitter has confirmed that the equipment produced at the factories documented in the Profile of Certification Reports will be in accordance with the Certification Reports in the Master File.

Proximity switches, inductive, for use with Certified special use supply cords, Types:

B(N)i.-(E)G (GT, M, MT, P or S).-A (R or F) Z3X.-B..., 5-500mA, 20-250V ac;

B(N)i.-(E)G (GT, M, MT, P or S).-A (R)Z 31X./33X.-B..., 5-100mA, 35-250V ac;



**Certificate:** 1063291 (LR 57940-3)

**Master Contract:** 154136

**Project:** 2230310

**Date Issued:** 2009/12/07

---

B(N)i.-(E)G (GT, M, MT, P or S).A (R)DZ 30X.-B..., 3-400mA, 20-250V ac, 20-300V dc ;  
DZ 32, 100 mA 250 V ac, 300 V dc.

Suffix B = connector.

Barrel proximity switches, inductive, with integral supply cords, Types:

B(N)i.-(E)G (GT, M, MT, P or S).-A (R or F) Z3X..., 5-500mA, 20-250V ac;

B(N)i.-(E)G (GT, M, MT, P or S).-A (R)Z 31X/33X..., 5-100mA, 35-250V ac;

B(N)i.-(E)G (GT, M, MT, P or S).A (R)DZ 30X..., 3-400mA, 20-250V ac, 20-300V dc ;

DZ 32, 100 mA 250 V ac, 300 V dc.

(E) = Signifies optional "Stainless Steel (304 or 316)" barrel, the G,M describe threading.

#### **APPLICABLE REQUIREMENTS**

- CAN/CSA-C22.2 No. 0-M91(R2001) - General Requirements - Canadian Electrical Code, Part II
- CAN/CSA-C22.2 No. 14 - Industrial Control Equipment
- \*CSA C22.2 No. 42 - General Use Receptacles, Attachment Plugs and Similar Wiring Devices
- \*CSA-C22.2 No. 49 - Flexible Cords and Cables
- UL 508 - Industrial Control Equipment

\* Used as a guides.