

FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment

JBBS- a-bc1d/Ex. Junction Brick.

IS / I / 1 / ABCD / T4 Ta = 70°C - NI-2.406; Entity / FISCO*;

I / 0 / AEx ia IIC / T4 Ta = 70°C - NI-2.406; Entity / FISCO*;

NI-ANI / I / 2 / CD / T4 Ta = 70°C - NI-2.406

Rectangular output characteristic-NIFW*

*For Entity, FISCO, and Nonincendive Field Wiring Parameters, refer to the relevant control drawings.

a = Bus standard: 48SC or 49SC.

b = Connector style: E, M, or T.

c = Number of spurs: 4 or 6.

d = Connector material: 3, 4, or 5.

Special Condition of Use:

1. In Division 2 installations, if the installation of this Junction Brick uses a wiring method other than nonincendive field wiring, then this Junction Brick may be installed in Group A / B areas, using the Approved lokfast Guard and ITC or PLTC cable types as defined by the NEC®.

JBBS- a-bc1d/Ex. Junction Brick.

IS / I / 1 / ABCD / T4 Ta = 70°C - NI-2.406; Entity / FISCO*;

I / 0 / AEx ia IIC / T4 Ta = 70°C - NI-2.406; Entity / FISCO*;

NI / I / 2 / ABCD / T4 Ta = 70°C

*For Entity and FISCO Parameters, refer to the relevant control drawings.

a = Bus standard: 48 or 49.

b = Connector style: E, M, or T.

c = Number of spurs: 4 or 6.

d = Connector material: 3, 4, or 5.

Special Conditions of Use:

1. In Division 2 installations, all cabling drops must be ITC or PLTC cable types as defined by the NEC®, using the Approved lokfast Guard.

2. Use Turck installation drawing NI-2.406 in addition to NEC®.

JRBS- a-bcEx. Junction Blocks.

IS / I / 1 / ABCD / T4 Ta = 70°C - NI-2.405; Entity / FISCO*;

I / 0 / AEx ia IIC / T4 Ta = 70°C - NI-2.405; Entity / FISCO*;

NI-ANI / I / 2 / CD / T4 Ta = 70°C - NI-2.405; Rectangular output characteristic-NIFW*

*For Entity, FISCO, and Nonincendive Field Wiring Parameters, refer to the relevant control drawings.

a = Bus standard: 40 or 40SC.

b = Number of spurs: 4, 6, or 8.

c = Terminal Type: C or R.

Special Conditions of Use:

1. In Division 2 installations, if the installation of this Junction Brick uses a wiring method other than nonincendive field wiring, then this Junction Brick may be installed in Group A / B areas, using Division 2 wiring methods as defined by the NEC®.

2. The Junction Blocks shall be installed in a tool secured enclosure in compliance with the mounting, spacing and segregation requirements of the ultimate application.

JRBS- a-bc/Ex. Junction Blocks.

IS / I / 1 / ABCD / T4 Ta = 70°C- NI-2.405; Entity / FISCO*;

I / 0 / AEx ia IIC / T4 Ta = 70°C- NI-2.405; Entity / FISCO*;

NI / I / 2 / ABCD / T4 Ta = 70°C

*For Entity and FISCO Parameters, refer to the relevant control drawings

a = Bus standard: 40.

b = Number of spurs: 4, 6, or 8.

c = Terminal Type: C or R

Special Condition of Use:

1. The Junction Blocks shall be installed in a tool secured enclosure in compliance with the mounting, spacing and segregation requirements of the ultimate application.

Equipment Ratings:

Intrinsically safe for use in Class I, Division 1, Groups A, B, C, & D; Class I, Zone 0, Group IIC;
Nonincendive for use in Class I, Division 2, Groups A, B, C, & D; indoor hazardous (classified) location
and Nonincendive field wiring with connection to Class I, Division 2, Groups C & D hazardous (classified)
location in accordance with control drawing NI-2.405 or NI-2.406.

The equipment has a Temperature Class T5, Ta = 70°C.

The Junction Blocks shall be installed in a final enclosure in order to retain its safety approval.

FM Approved for:

TURCK Inc.

Plymouth, Minnesota 55441, USA



This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	2011
Class 3810	2005
Class 3610	2010
Class 3611	2004
ANSI/ISA-60079-0	2009
ANSI/ISA-60079-11	2009

Original Project ID: 3025465

Approval Granted: May 11, 2006

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
090722	11/03/2009		
3042273	03/22/2012		

FM Approvals LLC

Timothy Adam
Technical Team Manager

Mar. 22, 2012
Date
