



FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmaprovals.com

Member of the FM Global Group

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

**Bi a-bcdef-gh6k-l/S1751/p, Bi a-bcdef-gh6k-mn41/S1751/p, BIM-bM12f-gP6k-H1141/S1751/p, Ni a-bcdef-gh6k-l/S1751/p, and Ni a-bcdef-gh6k-mn41/S1751/p
Cylindrical Inductive Proximity Sensors**

NI / I / 2 / ABCD / T4A Ta = 70°C; IP67 — NI-2.409

a = Sensing distance in mm

b = Housing material: E or blank

c = Housing style: G, M, P or S (P or S only with 18 or 30 mm diameter housing options)

d = Housing coating: T or blank

e = Housing diameter: 12, 18, or 30

f = Housing style modifier: E, K, M, T or blank

g = Output function: A or R

h = Output type: P or N

k = LED indication: X, X2 or blank

l = Integral cord length: length in meters followed by 'M', or blank for 2 meter cord

m = Connector type: B1, B2, or H1

n = Connector transition: 1, 3, or 4

p = Options: F2, S34, S100, S1589

Special Condition of Use:

1. Shall be installed in compliance with the enclosure, mounting, spacing and segregation requirements of the ultimate application including provisions for Division 2 wiring method and access only by the use of a tool.

Bi a-c-de6f- gh41/S1751/k and Ni ab-c-de6f- gh41/S1751/k Rectangular Inductive Proximity Sensors

NI / I / 2 / ABCD / T4A Ta = 70°C; IP67 — NI-2.409

a = Sensing distance in mm

b = Sensing technology: U or blank

c = Housing style: CP80, Q80 or Q20

d = Output function: A or R

e = Output type: P or N
f = LED indication: X, X2 or blank
g = Connector type: B1, B2, or H1
h = Connector transition: 1, 3 or 4
k = Options: F2, S34, S100, S1589

Special Condition of Use:

1. *Shall be installed in compliance with the enclosure, mounting, spacing and segregation requirements of the ultimate application including provisions for Division 2 wiring method and access only by the use of a tool.*

Equipment Ratings:

Nonincendive apparatus for use in Class I, Division 2, Groups A, B, C & D; Suitable for IP 67 indoor/outdoor hazardous (classified) locations, in accordance with control drawing NI-2.409. The temperature Class is T4A @ Ta = 70°C

FM Approved for:

Turck Inc.
3000 Campus Drive
Minneapolis, MN 55441

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	1998
Class 3611	2004
Class 3810	2005
IEC 60529	2001

Original Project ID: 3030545

Approval Granted: July 3, 2008

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
090921	November 5, 2009		

FM Approvals LLC


J.E. Marquedant
Group Manager, Electrical

5 November 2009
Date