



EU-TYPE-EXAMINATION CERTIFICATE (1)

(Translation)

- (2)Equipment or Protective Systems Intended for Use in Potentially Explosive Atmospheres - Directive 2014/34/EU
- (3) EU-Type Examination Certificate Number:

PTB 03 ATEX 2217

Issue: 1

(4)Product: Excom modul, type Al401Ex

(5)Manufacturer: Hans Turck GmbH & Co. KG

(6)Address: Witzlebenstraße 7, 45472 Mülheim an der Ruhr, Germany

- (7)This product and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.
- The Physikalisch-Technische Bundesanstalt, notified body No. 0102 in accordance with Article 17 of the (8)Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres, given in Annex II to the Directive.

The examination and test results are recorded in the confidential Test Report PTB Ex 17-26241.

- (9)Compliance with the Essential Health and Safety Requirements has been assured by compliance with: EN 60079-11:2012 EN 60079-0:2012+A11:2013
- (10) If the sign "X" is placed after the certificate number, it indicates that the product is subject to the Specific Conditions of Use specified in the schedule to this certificate.
- (11) This EU-Type Examination Certificate relates only to the design and construction of the specified product in accordance to the Directive 2014/34/EU. Further requirements of the Directive apply to the manufacturing process and supply of this product. These are not covered by this certificate.
- (12) The marking of the product shall include the following:

⟨Éx⟩ || 2(1) G Ex ib [ia Ga] ||C T4 Gb or Ex ib [ia Ga] ||C T4 II (1) D [Ex ia Da] IIIC or [Ex ia] IIIC

Konformitätsbewertungsstelle, Sektor Explosionsschutz CHNISCHE

Braunschweig, October 25, 2017

On behalf of PTB:

Dr.-Ing. F. Lienesch Direktor und Professo

sheet 1/5





(13)

SCHEDULE

(14) EU-Type Examination Certificate Number PTB 03 ATEX 2217, Issue: 1

(15) Description of Product

The Excom module, type Al401Ex is an analog input module which converts analog signals from sensors in intrinsically safe field circuits into binary signals for further processing in field bus systems. It provides inputs for active sensors and inputs for passive sensors.

It is designed in type of protection Intrinsic Safety "i" and it is intended to be used within the I/O Fieldbus system type excom® with the module subrack, type MT according to PTB 00 ATEX 2194 U.

The excom module, type Al401Ex ensures the electrical isolation for the various circuits. These isolate the external field circuits from the internal data buses and the internal supply voltage.

The operation of the excom module, type Al401Ex inside of an enclosure with a degree protection of at least IP54 is ensured by the application within the I/O Fieldbus system type excom® in potentially explosive atmospheres.

The permissible ambient temperature range is: -20°C up to +70°C

Electrical data

I.) AC-supply circuit type of protection Intrinsic Safety Ex ib IIC;

only for connection to the module subrack, type MT according PTB 00 ATEX 2194 U

P = 2.2 W (power consumption)

The intrinsically safe AC-supply circuit is safely electrically isolated from ground and up to a peak value of the nominal voltage of 60V from all other intrinsically safe circuits.

II.) Signal circuit (CAN-BUS) type of protection Intrinsic Safety Ex ib IIC;

only for connection to the module subrack type

MT according PTB 00 ATEX 2194 U

III.) Address encoding type of protection Intrinsic Safety Ex ib IIC:

only for connection to the module subrack type

MT according PTB 00 ATEX 2194 U

sheet 2/5





SCHEDULE TO EU-TYPE EXAMINATION CERTIFICATE PTB 03 ATEX 2217, Issue: 1

IV.) Field circuits

Inputs for active sensors

Channel 1: 13+, 14-Channel 2: 23+, 24-Channel 3: 33+, 34-Channel 4: 43+, 44type of protection Intrinsic Safety [Ex ia Ga] IIC/IIB or [Ex ia Da] IIIC maximum values per channel:

 $U_o = 6 V$ $I_o = 2.5 \text{ mA}$ $P_o = 4 \text{ mW}$ linear characteristic C_i negligibly low L_i negligibly low

maximum values for common external reactances:

(the values below correspond to the ISpark program 6.2)

	IIC	IIB
L _o (mH)	C₀ (µF)	C _o (µF)
5	2	10
2	2.3	12
1	2.6	14
0.5	3	17
0.2	3.7	22

or

Channel 1: 11+, 12-

Channel 2: 21+, 22-Channel 3: 31+, 32-

Channel 4: 41+, 42-

for interconnection of the field circuits with active sensors

type of protection Intrinsic Safety Ex ia IIC/IIB or Ex ia IIIC according to separate certificate maximum values per channel:

 $U_i = 30 \text{ V}$ $I_i = 107 \text{ mA}$ $P_i = 644 \text{ mW}$

V.) Field circuits type of protection Intrinsic Safety [Ex ia Ga] IIC/IIB or [Ex ia Da] IIIC Inputs for passive sensors maximum values per channel:

 $U_o = 19 \text{ V}$ $I_o = 90 \text{ mA}$ $P_o = 615 \text{ mW}$ C_i negligibly low L_i negligibly low

sheet 3/5



SCHEDULE TO EU-TYPE EXAMINATION CERTIFICATE PTB 03 ATEX 2217, Issue: 1

maximum values for common external reactances:

(the values below correspond to the ISpark program 6.2)

	IIC	IIB
L _o (mH)	C₀ (µF)	C₀ (µF)
2		0.97
1		0.97
0.5	0.12	0.97
0.2	0.17	1.1
0.1	0.20	1.3

All four channels may also be connected to the inputs to **IV**) **field circuits** with active intrinsically safe circuits whose intrinsically safe values do not exceed the aforementioned parameters. Only passive intrinsically safe circuits may be connected to the inputs to **V**) **field circuits**.

Either one passive sensor or one active sensor shall be assigned to each channel.

The intrinsically safe channels of the field circuits are safely electrically isolated from ground and from each other and - up to a peak value of the nominal voltage of 60V - from all other intrinsically safe circuits. In each channel, the inputs for passive and active sensors are electrically interconnected.

Modifications

The modifications concern the adaptation to the standards. The internal structure has been adapted. The changes concern the use of alternative components in the electronic circuitry.

- (16) Test Report PTB Ex 17-26241
- (17) Specific conditions of use





SCHEDULE TO EU-TYPE EXAMINATION CERTIFICATE PTB 03 ATEX 2217, Issue: 1

(18) Essential health and safety requirements

Met by compliance with the aforementioned standards.

According to Article 41 of Directive 2014/34/EU, EC-type examination certificates which have been issued according to Directive 94/9/EC prior to the date of coming into force of Directive 2014/34/EU (April 20, 2016) may be considered as if they were issued already in compliance with Directive 2014/34/EU. By permission of the European Commission supplements to such EC-type examination certificates and new issues of such certificates may continue to hold the original certificate number issued before April 20, 2016.

Konformitätsbewertungsstelle, Sektor Explosionsschutz

Braunschweig, October 25, 2017

Dr.-Ing. F. Lienesch Direktor und Profes

On behalf of PTB:



Braunschweig und Berlin



(1) EC-TYPE-EXAMINATION CERTIFICATE

(Translation)

- (2) Equipment and Protective Systems Intended for Use in Potentially Explosive Atmospheres **Directive 94/9/EC**
- (3) EC-type-examination Certificate Number:



PTB 03 ATEX 2217

- (4) Equipment: Analog input, type Al40Ex...
 (5) Manufacturer: Hans Turck GmbH & Co KG
- (6) Address: Witzlebenstr. 7, 45472 Mülheim, Germany
- (7) This equipment and any acceptable variation thereto are specified in the schedule to this certificate and the documents therein referred to.
- (8) The Physikalisch-Technische Bundesanstalt, notified body No. 0102 in accordance with Article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres, given in Annex II to the Directive.

The examination and test results are recorded in the confidential report PTB Ex 03-23439.

(9) Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN 50014:1997 + A1 + A2

EN 50020:2002

- (10) If the sign "X" is placed after the certificate number, it indicates that the equipment is subject to special conditions for safe use specified in the schedule to this certificate.
- (11) This EC-type-examination Certificate relates only to the design, examination and tests of the specified equipment in accordance to the Directive 94/9/EC. Further requirements of the Directive apply to the manufacturing process and supply of this equipment. These are not covered by this certificate.
- (12) The marking of the equipment shall include the following:

€x⟩	II 2 (1G/D)	G	EEx	ib	[ia]	IIC	T4
-----	--------	-------	---	-----	----	------	-----	----

Zertifizierungsstelle Explosionsschutz By order:

Braunschweig, August 23, 2004

by craci.

(signature)

Dr.-Ing. U. Johannsmeyer Regierungsdirektor

4 pages, correct and complete as regards content.

By order:

•

Dr.-Ing. Johannsmeyer Direktor und Professor

ly 1, 2005

sheet 1/4



Braunschweig und Berlin

SCHEDULE (13)

EC-TYPE-EXAMINATION CERTIFICATE PTB 03 ATEX 2217 (14)

(15) Description of equipment

The analog input, type Al40Ex... converts analog field signals into binary signals for the processing in fieldbus systems. Each channel provides a non-feeding input for active sensors and a feeding input for passive sensors. The module, type Al40Ex... forms part of the fieldbus system excom manufactured by Turck and shall only be operated in combination with the module subrack of type MT... according to PTB 00 ATEX 2194 U in the hazardous area of category 2G. The intrinsically safe field circuits may be conducted into areas of category 1G or

The degree of protection IP20 acc. to IEC 60529 is guaranteed when the module is plugged into the subrack MT...

The range of the ambient temperature is: -20 °C up to +60 °C.

The type of protection is: (x) II 2 (1G/D) G EEx ib [ia] IIC T4

Electrical data

I.) AC-supply circuit

(J2:15, 16)

Only for connection to the certified intrinsically safe circuit according to PTB 00 ATEX 2194 U in type of protection Intrinsic Safety EEx ib IIC with the following maximum values:

V AC (amplitude) $U_{max} = 20$

= 300 ... 314 kHz

P = 3.5 W (input power)

1.5 W (power consumption in the module)

C_i negligibly low negligibly low

The intrinsically safe AC-supply circuit is safely electrically isolated from ground and - up to a peak value of the nominal voltage of 60 V - from all other intrinsically safe circuits.

II) Signal circuit (CAN-Bus)

exclusively system-internal circuit, no external connection facilities

CAN-Bus A J2: 9, 10 CAN-Bus B J2:11, 12

sheet 2/4



Braunschweig und Berlin

SCHEDULE TO EC-TYPE-EXAMINATION CERTIFICATE PTB 03 ATEX 2217

III) Address encoding circuit

exclusively system-internal circuit, no external connection facilities (soldered intrinsically safe circuitry on backplane J2:1 through 6)

IV) Field circuit for active sensors

terminal clamps at the system module subrack for:

channel 1: 3, 4 channel 2: 7, 8 channel 3: 11, 12 channel 4: 15, 16 type of protection Intrinsic Safety EEx ia IIC/IIB with the following maximum values:

 $\begin{array}{lll} U_0 & \leq & 6.0 \ V \\ I_0 & \leq 45 & mA \\ P_0 & \leq 68 & mW \end{array}$

internal capacitance: $C_i = 24.2 \text{ nF}$ internal inductance: L_i negligibly low

characteristic: linear

	EEx ia IIC	EEx ia IIB
L _o (mH)	10	20
C _o (nF)	1400	7300

The following maximum values apply for the infeed from active sensors of type of protection Intrinsic EEx ia IIC/IIB:

Linear characteristic (a) $U_i \leq 30 \text{ V}$

 $I_i \leq 72 \text{ mA}$

 $P_i \leq 540 \ mW$

Linear characteristic (b) $U_i \le 22 V$

 $I_i \leq 98 \text{ mA}$

P_i ≤ 540 mW

Trapezoidal characteristic (including rectangular characteristic)

 $U_i \leq 30 V$

 $I_i \leq 45 \text{ mA}$

 $P_i \leq 540 \text{ mW}$



Braunschweig und Berlin

SCHEDULE TO EC-TYPE-EXAMINATION CERTIFICATE PTB 03 ATEX 2217

V) Field circuit for passive sensors, feeding

terminal clamps at the system module subrack for: channel 1: 1, 2 channel 2: 5, 6 channel 3: 9, 10 channel 4: 13, 14 type of protection Intrinsic Safety EEx ia IIC/IIB with the following maximum values:

 $\begin{array}{lll} U_0 & \leq & 19.1 & V \\ I_0 & \leq & 90 & mA \\ P_0 & \leq 800 & mW \end{array}$

internal capacitance: $C_i = 24.2 \text{ nF}$ internal inductance: L_i negligibly low characteristic: trapezoidal

 $R_i = 134 \Omega$ $U_0 = 23.3 V$

The internal capacitance has already been considered in the following table:

	EEx ia IIC	EEx ia IIB
L _o (mH)	0.20	1.00
C _o (µF)	0.125	0.87

The non-feeding field circuits for active sensors and the feeding field circuits for passive sensors are electrically interconnected within the respective channel. The channels, however, are electrically isolated from each other up to a voltage of 30 V.

(16) <u>Test report</u> PTB Ex 03-23439

(17) Special conditions for safe use

none

(18) Essential health and safety requirements

met by compliance with the standards mentioned above

Zertifizierungsstelle Explosionsschutz By order:

Braunschweig, August 23, 2004

(signature)

Dr.-Ing. U. Johannsmeyer Regierungsdirektor

sheet 4/4



Braunschweig und Berlin

1. SUPPLEMENT

according to Directive 94/9/EC Annex III.6

to EC-TYPE-EXAMINATION CERTIFICATE PTB 03 ATEX 2217

(Translation)

Equipment: Analog input, type Al401.. or Al40Ex...

Marking: (I) G Ex ib[ia] IIC T4 and II (1) D Ex [iaD]

Manufacturer: Hans Turck GmbH & Co. KG

Address: Witzlebenstraße 7, 45472 Mülheim an der Ruhr, Germany

Description of supplements and modifications

The Excom module of type Al40Ex is supplemented by type Al401.. and may in future also be manufactured according to the test documents listed in the assessment and test report.

The modifications concern the internal and external construction.

The permissible range of the ambient temperature is -20 °C ... 70 °C.

The marking has been adapted to the state of the standards.

All other specifications of the EC-type examination certificate apply without changes.

Electrical data

I.) AC-supply circuit (J2: 15, 16)

System-internal circuit in type of protection Intrinsic Safety Ex ib IIC/IIB or Ex iaD without external connection facilities. Only for connection to the certified intrinsically safe circuit according to PTB 00 ATEX 2194 U

Maximum values:

 U_{max} = 20 V AC (amplitude)

f = 300 ... 314 kHz

P = 3.5 W (input power)

P = 1.5 W (power consumption in the module)

C_i negligibly lowL_i negligibly low

The intrinsically safe AC-supply circuit is safely electrically isolated from ground and - up to a peak value of the nominal voltage of 60 V - from all other intrinsically safe circuits.

Sheet 1/3



Braunschweig und Berlin

1. SUPPLEMENT TO EC-TYPE-EXAMINATION CERTIFICATE PTB 03 ATEX 2217

II) Signal circuit (CAN-Bus) (J2: 9, 10 CAN-Bus A) (J2: 11, 12 CAN-Bus B)

system-internal circuit, without external connection facilities

III) Address encoding circuit (J2: 1...6)

system-internal circuit, without external connection facilities

IV) Field circuit for active sensors

terminal clamps at the system module subrack for:

channel 1: 3, 4 channel 2: 7, 8 channel 3: 11, 12 channel 4: 15, 16) type of protection Intrinsic Safety Ex ia IIC/IIB or Ex iaD

Type Al401... Type Al40Ex $U_0 \leq$ 6.0 V U₀ ≤ 6.0 V $I_0 \leq$ 2.5 $I_0 \leq$ 45 mA mΑ $P_0 \leq$ $P_0 \leq$ 4 68 mW mW linear characteristic linear characteristic C_i negligibly low 24.2 nF

L_i negligibly low Li negligibly low

Туре		Ex ia IIC	Ex ia IIB
Al401	Lo	10 mH	20 mH
	Co	1.9 µF	8.6 µF
Al40Ex	Lo	10 mH	20 mH
	C _o	1.4 µF	7.1 µF

The following maximum values apply to the infeed from active sensors of type of protection Intrinsic Safety Ex ia IIC/IIB or Ex iaD:

Type Al401.. V U_i ≤ 30 \leq 107 mA

644 mW

Type Al40Ex

characteristic linear V (a) Ui 30 \leq

72 \leq mA

540 mW

 U_i 22 V (b) \leq or ≤ 98 mA

 \leq 540 mW

characteristic trapezoidal V U_i 30 \leq or rectangular

45 \leq mΑ 540 mW

Sheet 2/3



Braunschweig und Berlin

1. SUPPLEMENT TO EC-TYPE-EXAMINATION CERTIFICATE PTB 03 ATEX 2217

IV) Field circuit

.....type of protection Intrinsic Safety Ex ia IIC/IIB

or Ex iaD

for passive sensors, feeding (terminal clamps at the

system module subrack for:

channel 1: 1, 2 channel 2: 5, 6 channel 3: 9, 10 channel 4: 13, 14) Maximum values per channel:

For relationship between type of equipment and electrical parameters, reference is made to the table

Type	Al401 Al40Ex		
Ü。	19.1 V	19.1 V	
I _o	90 mA	90 mA	
P _o	615 mW	800 mW	
R _i	304 Ω	134 Ω	
Ci	negligibly low	24.2 nF	
Li	negligib	ly low	
characteristic	trapezoidal		

Туре		Ex ia IIC	Ex ia IIB
Al401	Lo	0.2 mH	1 mH
	Co	0.17 µF	0.96 µF
Al40Ex	Lo	0.2 mH	1 mH
	Co	0.125 µF	0.87 μF

The internal capacitance has already been considered with the tabulated values

The non-feeding field circuits for active sensors and the feeding field circuits for passive sensors are electrically interconnected within the respective channel. The channels, however, are electrically isolated from each other up to a voltage of 30 V.

Applied standards

EN 60079-0:2006

EN 60079-11:2007

EN 61241-0:2006

EN 61241-11:2006

Assessment and test report:

PTB Ex 10-20066

Zertifizierungssektor Explosionssch On behalf of P/TB:

011 501101 01 1/12.

Braunschweig, August 4, 2010

Dr.-Ing. U. Johannsme Direktor und Professor

Sheet 3/3



Braunschweig und Berlin

2. SUPPLEMENT

according to Directive 94/9/EC Annex III.6

to EC-TYPE-EXAMINATION CERTIFICATE PTB 03 ATEX 2217

(Translation)

Equipment:

Analog input, type Al401... or Al40Ex...

Marking:

II 2 (1) G Ex ib[ia] IIC T4 and II (1) D [Ex iaD]

Manufacturer: Hans Turck GmbH & Co. KG

Address:

Witzlebenstraße 7, 45472 Mülheim an der Ruhr, Germany

Description of supplements and modifications

The marking has been corrected.

All other specifications of the EC-type examination certificate apply without changes.

Applied standards

EN 60079-0:2006

EN 60079-11:2007

EN 61241-0:2006

EN 61241-11:2006

Assessment and test report:

PTB Ex 10-20066

Zertifizierungssektor Explosionsschutz On behalf of PTB:

Braunschweig, September 13, 2010

(signature)

Dr.-Ing. U. Johannsmeyer Direktor und Professor

1 page, correct and complete as regards content. By order:

Dipl.-Ing. Wilk

Braunschweig, October 8, 2010

Sheet 1/1